

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

HU-001991

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

PVC insulated single-core non-sheathed cable with flexible conductor for internal wiring for a conductor temperature of 70°C

Name and address of the applicant

KISEONG CABLE, INC.
(Sinpyeong-dong) 219, Jangpyeong-ro, Saha-gu,
Busan, 49439 Rep.of Korea

Name and address of the manufacturer

KISEONG CABLE, INC.
(Sinpyeong-dong) 219, Jangpyeong-ro, Saha-gu,
Busan, 49439 Rep.of Korea

Name and address of the factory

KISEONG CABLE, INC.
(Sinpyeong-dong) 219, Jangpyeong-ro, Saha-gu,
Busan, 49439 Rep.of Korea

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Rated voltage: 300/500V;
Class 5 conductor, 0.5mm², 0.75mm², 1mm²

Trademark (if any)

KISEONG

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

60227 IEC 06 (H05V-K)

Additional information (if necessary may also be reported on page 2)

Additional tests according to EN 50525-2-31

A sample of the product was tested and found to be in conformity with

IEC 60227-3:1993 + AMD1:1997
IEC 60227-2:1997 + AMD1:2003
IEC 60227-1:2007
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

28237663 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2017-06-21

Signature:

Kassai
Gabor Kassai

